This document is meant purely as a documentation tool and the institutions do not assume any liability for its contents

►**B**

COMMISSION DECISION

of 8 February 2000

implementing Council Directive 89/106/EEC as regards the classification of the reaction to fire performance of construction products

(notified under document number C(2000) 133)

(Text with EEA relevance)

(2000/147/EC)

(OJ L 50, 23.2.2000, p. 14)

Amended by:

	Official Journal		
	No	page	date
►**M1** Commission Decision 2003/632/EC of 26 August 2003	L 220	5	3.9.2003

Corrected by:

►**C1** Corrigendum, OJ L 85, 24.3.2001, p. 43 (2000/147/EC)

▼B

COMMISSION DECISION

of 8 February 2000

implementing Council Directive 89/106/EEC as regards the classification of the reaction to fire performance of construction products

(notified under document number C(2000) 133)

(Text with EEA relevance)

(2000/147/EC)

THE COMMISSION OF THE EUROPEAN COMMUNITIES,

Having regard to the Treaty establishing the European Community,

Having regard to Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products ([1]), as amended by Directive 93/68/EEC ([2]), and in particular Articles 3, 6 and 20 thereof,

Whereas:

(1) Article 3(2) and (3) of Directive 89/106/EEC state that in order to take account of different levels of protection for the construction works that may prevail at national, regional or local levels, each essential requirement may give rise to the establishment of classes in the interpretative documents. These documents have been published as the 'Communication of the Commission with regard to the interpretative documents of Council Directive 89/106/EEC ([3])'.

(2) Paragraph 4.2.1 of interpretative document No 2 justifies the need for different levels of the essential requirement as function of the type, use and location of the construction work, its layout and the availability of the emergency facilities.

(3) Paragraph 2.2 of interpretative document No 2 lists a number of interrelated measures for the satisfaction of the essential requirement, 'Safety in case of fire' that together contribute to define the fire safety strategy that can be developed in different ways in Member States.

(4) Paragraph 4.2.3.3 of interpretative document No 2 identifies one of these measures prevailing in Member States that consists in the limitation of the generation and spread of fire and smoke within the room of origin (or in a given area) by limiting the contribution of construction products to the full development of a fire.

(5) The definition of classes of the essential requirement partially depends on the level of such a limitation.

(6) The level of this limitation may be expressed only by different levels of reaction to fire performance of the products in their end-use application.

(7) Paragraph 4.3.1.1 of the interpretative document No 2 specifies that to enable the reaction to fire performance of products to be evaluated, a harmonised solution will be developed which may utilise full or bench scale tests that are correlated to relevant real fire scenarios.

(8) The harmonised solution lies in a system of classes that are not included in the interpretative document.

(9) The system of classes identified for this purpose refers to a number of test methods already known to the European standardisation bodies.

([1]) OJ L 40, 11.2.1989, p. 12.
([2]) OJ L 220, 30.8.1993, p. 1.
([3]) OJ C 62, 28.2.1994, p. 1.

▼B

(10) Commission Decision 94/611/EC of 9 September 1994 on the application of Article 20 of Directive 89/106/EEC relating to construction products ([1]), which describes the system of classes, does not indicate the thresholds of classes B, C and D, as the single burning item test was not sufficiently well developed at that time.

(11) The relevant data are now available and Decision 94/611/EC should therefore be replaced by a new decision which includes the thresholds of the classes and some adaptations to technical progress. Alternative test procedures should be fully described in a future European standard, or Commission decision, on the basis of an agreement between the Commission and the Member States, in consultation with CEN/CENELEC and EOTA.

(12) The measures provided for in this Decision are in accordance with the opinion of the Standing Committee on Construction,

HAS ADOPTED THIS DECISION:

Article 1

1. When the end-use application of a construction product is such that it may contribute to the generation and spread of fire and smoke within the room (or area) of origin or beyond, the product shall be classified on the basis of its reaction to fire performance, having regard to the classification system set out in Tables 1 and 2 of the Annex.

2. Products shall be considered in relation to their end-use application.

If the classification based on the standardised tests and criteria listed in Tables 1 and 2 of the Annex is not appropriate, one or more reference scenarios (representative scale test(s) typifying agreed hazard scenario(s)) may be called on, within the context of a procedure providing for alternative tests.

Article 2

Decision 94/611/EC is hereby repealed.

References to the repealed Decision shall be construed as references to this Decision.

Article 3

This Decision is addressed to the Member States.

([1]) OJ L 241, 16.9.1994, p. 25.

▼B

ANNEX

Symbols ([1])

ΔT	temperature rise
Δm	mass loss
t_f	duration of flaming
PCS	gross calorific potential
FIGRA	fire growth rate
THR_{600s}	total heat release
LFS	lateral flame spread
SMOGRA	smoke growth rate
TSP_{600s}	total smoke production
Fs	flame spread

Definitions

‘Material’: a single basic substance or uniformly dispersed mixture of substances, for example metal, stone, timber, concrete, mineral wool with uniformly dispersed binder, polymers.

‘Homogeneous product’: a product consisting of a single material, having uniform density and composition throughout the product.

‘Non-homogeneous product’: a product that does not satisfy the requirements of a homogeneous product. It is a product composed of one or more components, substantial and/or non-substantial.

‘Substantial component’: a material that constitutes a significant part of a non-homogeneous product. A layer with a mass per unit area $\geq$ 1,0 kg/m^2 or a thickness $\geq$ 1,0 mm is considered to be a substantial component.

‘Non-substantial component’: a material that does not constitute a significant part of a non-homogeneous product. A layer with a mass per unit area < 1,0 kg/m^2 and a thickness < 1,0 mm is considered to be a non-substantial component.

Two or more non-substantial layers that are adjacent to each other (i.e. with no substantial component(s) in-between the layers) are regarded as one non-substantial component and, therefore, must altogether comply with the requirements for a layer being a non-substantial component.

For non-substantial components, distinction is made between internal non-substantial components and external non-substantial components, as follows.

‘Internal non-substantial component’: a non-substantial component that is covered on both sides by at least one substantial component.

‘External non-substantial component’: a non-substantial component that is not covered on one side by a substantial component.

([1]) The characteristics are defined with respect to the appropriate test method.

▼B

Table 1

CLASSES OF REACTION TO FIRE PERFORMANCE FOR CONSTRUCTION PRODUCTS EXCLUDING FLOORINGS (*)

Class	Test method(s)	Classification criteria	Additional classification
A1	EN ISO 1182 (1) and	$\Delta T \leq 30$ ºC; and $\Delta m \leq 50$ %; and $t_f = 0$ (i.e. no sustained flaming)	—
	EN ISO 1716	PCS $\leq$ 2,0 MJ.kg^{-1} (1) and PCS $\leq$ 2,0 MJ.kg^{-1} (2) (2a) and PCS $\leq$ 1,4 MJ.m^{-2} (3) and PCS $\leq$ 2,0 MJ.kg^{-1} (4)	—
A2	EN ISO 1182 (1) or	$\Delta T \leq 50$ ºC and $\Delta m \leq 50$ % and $t_f \leq 20$s	—
	EN ISO 1716 and	PCS $\leq$ 3,0 MJ.kg^{-1} (1) and PCS $\leq$ 4,0 MJ.m^{-2} (2) and PCS $\leq$ 4,0 MJ.m^{-2} (3) and PCS $\leq$ 3,0 MJ.kg^{-1} (4)	—
	EN 13823 (SBI)	FIGRA $\leq$ 120 W.s^{-1} and LFS < edge of specimen and $THR_{600s} \leq$ 7,5 MJ	Smoke production (5), and flaming droplets/ particles (6)
B	EN 13823 (SBI) and	FIGRA $\leq$ 120 W.s^{-1} and LFS < edge of specimen and $THR_{600s} \leq$ 7,5 MJ	Smoke production (5), and flaming droplets/ particles (6)
	EN ISO 11925-2 (8) *Exposure = 30s*	Fs $\leq$ 150 mm within 60s	
C	EN 13823 (SBI) and	FIGRA $\leq$ 250 W.s^{-1} and LFS < edge of specimen and $THR_{600s} \leq$ 15 MJ	Smoke production (5), and flaming droplets/ particles (6)
	EN ISO 11925-2 (8): *Exposure = 30s*	Fs $\leq$ 150 mm within 60s	
D	EN 13823 (SBI) and	FIGRA $\leq$ 750 W.s^{-1}	Smoke production (5), and flaming droplets/ particles (6)
	EN ISO 11925-2 (8): *Exposure = 30s*	Fs $\leq$ 150 mm within 60s	
E	EN ISO 11925-2 (8) *Exposure = 15s*	Fs $\leq$ 150 mm within 20s	Flaming droplets/particles (7)
F	No performance determined		

(*) The treatment of some families of products, e.g. linear products (pipes, ducts, cables, etc.), is still under review and may necessitate an amendment to this decision.

(1) For homogeneous products and substantial components of non-homogeneous products.

(2) For any external non-substantial component of non-homogeneous products.

(2a) Alternatively, any external non-substantial component having a PCS $\leq$ 2,0 MJ.m^{-2}, provided that the product satisfies the following criteria of EN 13823 (SBI): FIGRA $\leq$ 20 W.s^{-1}; and LFS < edge of specimen, and ►C1 THR_{600s} ◄ $\leq$ 4,0 MJ and s1 and d0.

(3) For any internal non-substantial component of non-homogeneous products.

(4) For the product as a whole.

(5) s1 = SMOGRA $\leq$ 30m^2.s^{-2} and ►C1 TSP_{600s} ◄ $\leq$ 50m^2; s2 = SMOGRA $\leq$ 180m^2.s^{-2} and $TSP_{600s} \leq$ 200m^2; s3 = not s1 or s2.

(6) d0 = No flaming droplets/particles in EN 13823 (SBI) within 600s; d1 = no flaming droplets/particles persisting longer than 10s in EN 13823 (SBI) within 600s; d2 = not d0 not d1; ignition of the paper in EN ISO 11925-2 results in a d2 classification.

▼B

(7) Pass = no ignition of the paper (no classification); fail = ignition of the paper (d2 classification).
(8) Under conditions of surface flame attack and, if appropriate to the end-use application of the product, edge flame attack.

Table 2

CLASSSES OF REACTION TO FIRE PERFORMANCE FOR FLOORINGS

Class	Test method(s)	Classification criteria	Additional classification
$A1_{FL}$	EN ISO 1182 (1) and	$\Delta T \leq 30$ ºC and $\Delta m \leq 50$ % and $t_f = 0$ (i.e. no sustained flaming)	—
	EN ISO 1716	PCS $\leq$ 2,0 MJ.kg^{-1} (1) and PCS $\leq$ 2,0 MJ.kg^{-1} (2) and PCS $\leq$ 1,4 MJ.m^{-2} (3) and PCS $\leq$ 2,0 MJ.kg^{-1} (4)	—
$A2_{FL}$	EN ISO 1182 (1) or	$\Delta T \leq 50$ ºC and $\Delta m \leq 50$ % and $t_f \leq 20$s	—
	EN ISO 1716 and	PCS $\leq$ 3,0 MJ.kg^{-1} (1) and PCS $\leq$ 4,0 MJ.m^{-2} (2) and PCS $\leq$ 4,0 MJ.m^{-2} (3) and PCS $\leq$ 3,0 MJ.kg^{-1} (4)	—
	EN ISO 9239-1 (5)	Critical flux (6) $\geq$ 8,0 kW.m^{-2}	Smoke production (7)
B_{FL}	EN ISO 9239-1 (5) and	Critical flux (6) $\geq$ 8,0 kW.m^{-2}	Smoke production (7)
	EN ISO 11925-2 (8) *Exposure = 15s*	►C1 Fs $\leq$ 150 mm within 20s ◄	
C_{FL}	EN ISO 9239-1 (5) and	Critical flux (6) $\geq$ 4,5 kW.m^{-2}	Smoke production (7)
	EN ISO 11925-2 (8) *Exposure = 15s*	Fs $\leq$ 150 mm within 20s	
D_{FL}	EN ISO 9239-1 (5) and	Critical flux (6) $\geq$ 3,0 kW.m^{-2}	Smoke production (7)
	EN ISO 11925-2 (8) *Exposure = 15s*	Fs $\leq$ 150 mm within 20s	
E_{FL}	EN ISO 11925-2 (8) *Exposure = 15s*	Fs $\leq$ 150 mm within 20s	
F_{FL}	No performance determined		

(1) For homogeneous products and substantial components of non-homogeneous products.
(2) For any external non-substantial component of non-homogeneous products.
(3) For any internal non-substantial component of non-homogeneous products.
(4) For the product as a whole.
(5) Test duration = 30 minutes.
(6) Critical flux is defined as the radiant flux at which the flame extinguishes or the radiant flux after a test period of 30 minutes, whichever is the lower (i.e. the flux corresponding with the furthest extent of spread of flame).
(7) s1 = Smoke $\leq$ 750 %.min; s2 = not s1.
(8) Under conditions of surface flame attack and, if appropriate to the end-use application of the product, edge flame attack.

▼M1

Table 3

CLASSES OF REACTION-TO-FIRE PERFORMANCE FOR LINEAR PIPE THERMAL INSULATION PRODUCTS

Class	Test method(s)	Classification criteria	Additional classification
$A1_L$	EN ISO 1182 (1); and	$\Delta T \leq 30$ ºC; and $\Delta m \leq 50$ %; and $t_f = 0$ (i.e. no sustained flaming)	—
	EN ISO 1716	PCS $\leq$ 2,0 MJ.kg^{-1} (1); and PCS $\leq$ 2,0 MJ.kg^{-1} (2); and PCS $\leq$ 1,4 MJ.m^{-2} (3); and PCS $\leq$ 2,0 MJ.kg^{-1} (4)	—
$A2_L$	EN ISO 1182 (1); or	$\Delta T \leq 50$ ºC; and $\Delta m \leq 50$ %; and $t_f \leq 20$s	—
	EN ISO 1716; and	PCS $\leq$ 3,0 MJ.kg^{-1} (1); and PCS $\leq$ 4,0 MJ.m^{-2} (2); and PCS $\leq$ 4,0 MJ.m^{-2} (3); and PCS $\leq$ 3,0 MJ.kg^{-1} (4)	—
	EN 13823 (SBI)	FIGRA $\leq$ 270 W.s^{-1}; and LFS < edge of specimen; and $THR_{600s} \leq$ 7,5 MJ	Smoke production (5); and Flaming droplets/particles (6)
B_L	EN 13823 (SBI); and	FIGRA $\leq$ 270 W.s^{-1}; and LFS < edge of specimen; and THR600s $\leq$ 7,5 MJ	Smoke production (5); and Flaming droplets/particles (6)
	EN ISO 11925-2 (8): Exposure = 30s	Fs $\leq$ 150mm within 60s	
C_L	EN 13823 (SBI); and	FIGRA $\leq$ 460 W.s^{-1}; and LFS < edge of specimen; and $THR_{600s} \leq$ 15 MJ	Smoke production (5); and Flaming droplets/particles (6)
	EN ISO 11925-2 (8): Exposure = 30s	Fs $\leq$ 150mm within 60s	
D_L	EN 13823 (SBI); and	FIGRA $\leq$ 2100 W.s^{-1} $THR_{600s} \leq$ 100 MJ	Smoke production (5); and Flaming droplets/particles (6)
	EN ISO 11925-2 (8): Exposure = 30s	Fs $\leq$ 150mm within 60s	
E_L	EN ISO 11925-2(8): Exposure = 15s	Fs $\leq$ 150mm within 20s	Flaming droplets/particles (7)
F_L	No performance determined		

(1) For homogeneous products and substantial components of non-homogeneous products.
(2) For any external non-substantial component of non-homogeneous products.
(3) For any internal non-substantial component of non-homogeneous products.
(4) For the product as a whole.
(5) s1 = SMOGRA $\leq$ 105 m^2.s^{-2} and $TSP_{600s} \leq$ 250 m^2; s2 = SMOGRA $\leq$ 580 m^2.s^{-2} and $TSP_{600s} \leq$ 1600 m^2; s3 = not s1 or s2.
(6) d0 = No flaming droplets/particles in EN13823 (SBI) within 600s; d1 = No flaming droplets/particles persisting longer than 10s in EN13823 (SBI) within 600s; d2 = not d0 or d1; ignition of the paper in EN ISO 11925-2 results in a d2 classification.
(7) Pass = no ignition of the paper (no classification); fail = ignition of the paper (d2 classification).
(8) Under conditions of surface flame attack and, if appropriate to end-use application of product, edge flame attack.